

VOC Content Test Certificate

Monday 10th August 2026

Supplier: ICCONS Pty Ltd (383 Frankston Dandenong Road, DANDENONG SOUTH, VIC 3175, Australia).

Product name: FSA-STU300-GS Glass and Glazing Ultimate 100% Silicone Sealant

Date Tested: July 2026 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-25 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	FSA-STU300-GS Glass and Glazing Ultimate 100% Silicone Sealant
General Purpose Adhesives and Sealants Limit: 50 grams per litre	38 grams per litre as VOC content per material
<i>We hereby certify FSA-STU300-GS Glass and Glazing Ultimate 100% Silicone Sealant is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant